

Yacht-Mate™

Products

QUICK START FOR CLACK DIGITAL VALVE

NOTE – THERE MUST BE A MANUAL SHUT OFF OR SOLENOID NORMALLY OPEN ON THE DISCHARGE LINE (ATTACHED TO THE SENSOR) N/O IT WILL CLOSE WHEN SENSOR OPENS BOAT PRESSURE SOLENOID N/C IN ORDER TO RECHARGE THE SYSTEM

SET UP 1st add 2 gallons water to brine tank

THEN SET TIME

THEN PUSH AND HOLD REGEN UNTIL IT SAYS BACKWASH

(UNIT GOES INTO BYPASS)

UNPLUG UNIT

TURN INLET WATER ON SLOWLY UNTIL AIR & COLOR ARE PURGED OUT TURN WATER FULL PRESSURE

PLUG UNIT BACK IN

PRESS REGEN IT SHOWS BRINE WAIT FOR MOTOR TO STOP

PRESS REGEN AGAIN SAYS BACKWASH WAIT FOR MOTOR TO STOP

PRESS REGEN AGAIN SAYS RINSE WAIT FOR MOTOR TO STOP

PRESS REGEN AGAIN SAYS FILL LEAVE IT ON TO FILL BRINE TANK WHEN THAT CYCLE STOPS YOU ARE DONE WITH STARTING UP

PROGRAMMING

PUSH NEXT & UP ARROW THEN SET HARDNESS

PUSH NEXT REGEN DAY ARROW UNTIL OFF APPEARS

PUSH NEXT REGEN TIME PRE SET TO 2 AM THIS IS FOR AUTO YOU CAN MANUALLY REGEN ANYTIME C 2 PROGRAMMING

PUSH NEXT SHOWS TIME

NOW PUSH NEXT & DOWN ARROW

ASK IF IT IS A SOFTENER OR FILTER USE ARROWS TO SELECT SOFTENER

PUSH NEXT TO SET CAPACITY 30,000

PUSH NEXT LBS REGEN 10lbs

NEXT NORMAL

NEXT AUTO (MEMORY)

NEXT PRE & POST FILL SELECT POST

NEXT DN FOR DOWN FLOW

NEXT NORMAL OR EXTENDED USE NORMAL

DIAIGNOSTICS

PRESS UP AND DOWN ARROW AT THE SAME TIME

SHOWS # OF DAYS SINCE LAST REGEN

NEXT # OF GALLONS

NEXT GALLONS LEFT

(NOTE: TO CHECK BEFORE DISCONNECTING WATER DOCKSIDE) IF USED AFTER PUMPS NO NEED TO CHECK

NOTES: REGEN / RECHARGE TAKES 1.5 HOURS USING APPROX 60 GALLONS
FOR TECHNICAL ASSISTANCE CALL 954-527-0112